



GRINDER PUMP TO SANITARY FORCE MAIN CONNECTION

NOT TO SCALE

- NOTE:
- GRINDER PUMP MUST BE AT LEAST 10 FEET FROM FOUNDATION.
 - ALL COMPRESSION FITTINGS WILL BE BRASS OR STAINLESS STEEL.

SARATOGA COUNTY SEWER DISTRICT #1
RESERVES THE RIGHT, AT OUR DISCRETION, TO
CHANGE, MODIFY, ADD OR REMOVE PORTIONS
OF THESE DETAIL SPECS AT ANY TIME



SARATOGA COUNTY SEWER DISTRICT #1

1002 HUDSON RIVER ROAD, MECHANICVILLE, NEW YORK