

NOTES:

- 1) NATIVE EXCAVATED GRANULAR MATERIAL MAY BE USED FOR BACKFILL IF APPROVED BY THE ENGINEER.
- CRUSHED STONE #1 AND #2, NOT TO EXCEED ONE (1) INCH IN SIZE. A.O.B.E. = AS ORDERED BY ENGINEER.
- 3) GRAVITY LINE SHALL BE SDR 21 OR 26, INCLUDING FITTINGS.
- 4) FORCE MAIN LINE SHALL BE C-900, DR 9 OR 11 (200 PSI MINIMUM).
- 5) THE GRAVITY SEWER LATERAL SHALL BE LAID AT A UNIFORM GRADE OF 1/4 INCH PER FOOT (ABOUT 2%).
- 6) WHERE A WATER TABLE CONDITION EXISTS, STONE BEDDING SHALL BE WRAPPED IN A NON-WOBEN GEO-TEXTILE ENVELOPE (FABRIC FOUNALENT TO PROPEX GEOTEX 451).
- 7) CONTRACTORS SHALL COMPLY WITH ALL LOCAL, STATE, AND FEDERAL SAFETY REGULATIONS.
- 8) TRACER WIRE SHALL BE GREEN IN COLOR.
- 9) TRACER WIRE SHALL BE A MINIMUM OF #10 GAUGE STRANDED STAINLESS STEEL.
- 10) TRACER WIRE SHALL BE APPROVED FOR HORIZONTAL DIRECTIONAL DRILLING (HDD) APPLICATIONS.
- 11) TRACER WIRE SHALL BE HIGH-DENSITY POLYETHYLENE (HDPE) INSULATED STRANDED STAINLESS STEEL OR APPROVED BY SCSD#1.



SARATOGA COUNTY SEWER DISTRICT #1
RESERVES THE RIGHT, AT OUR DISCRETION, TO
CHANGE, MODIFY, ADD OR REMOVE PORTIONS
OF THESE DETAIL SPEC'S AT ANY TIME

Telephone: (518) 664-7396

Fax: (518) 664-6280



SARATOGA COUNTY SEWER DISTRICT #1

1002 HUDSON RIVER ROAD, MECHANICVILLE, NEW YORK