



SARATOGA COUNTY SEWER DISTRICT #1 REQUIREMENTS FOR OIL AND SOLIDS INTERCEPTOR PERMIT APPLICATION

- All information on the Oil and Solids Interceptor Permit Application shall be completed.
- Interior Plumbing plans, Fixture plans and Fixture Schedule shall be submitted for review and approval of SCSD #1.
- Design calculations (per International Plumbing Code) for sizing oil and solids interceptor(s) shall be submitted for review and approval of SCSD #1.
 - Detail sheet of oil and solids Interceptor shall be submitted for review and approval of SCSD# 1.
 - Detail sheet(s) of fixtures connecting to oil and solids Interceptor shall be submitted for review and approval of SCSD #1.
- SCSD #1 will require the **contractor** to have a Certificate of Insurance listing **County of Saratoga, 40 McMaster Street, Ballston Spa, NY 12020** as certificate holder and an additional named insured prior to the signing of the permit. See Certificate of Insurance Sample Sheet.
- SCSD #1 requires that the permit fee be paid when submitting the permit application. Please refer to SCSD #1 permit fee schedule.